



Refrigeration and Air conditioning Engineering. 3rd year – refrigeration and Air conditioning Course

M.Sc. Zahraa F. Hussain





HEATING LOAD ESTIMATION

Lecture -5-

M.Sc. Zahraa F. Hussain

Msc. Zahraa F. Hussain

1.8 HEATING LOAD ESTIMATION

The heating load evaluation is the foundation for selecting the heating equipment. Normally, the heating load is estimated for the winter design temperatures (Table 2) usually occurring at night; therefore, no credit is taken for the heat given off by internal sources (people, lights, etc.). This estimate must take into account the heat loss thru the building structure surrounding the spaces and the heat required to offset the outdoor air which may infiltrate and/or may be required for ventilation.

HIGH ALTITUDE LOAD CALCULATIONS

Since air conditioning load calculations are based on liters of air necessary to handle a load, a decrease in density means an increase in Lit/s required to satisfy the given sensible load.

1- Heat Loss – Glass And Door

$$Q_{t/g} = \mathrm{U} \mathrm{A}_{\mathrm{g/d}} (\mathrm{T}_{\mathrm{i}} - \mathrm{T}_{\mathrm{o}})$$



2. HEAT LOSS – WALLS AND ROOFS

$$Q_{t/R} = \mathbf{U} \mathbf{A}_{\mathbf{R}} (\mathbf{T}_{\mathbf{i}} - \mathbf{T}_{\mathbf{o}})$$

Where

 $Q_{t/R} =$ Solar transmission Roof Or WallWU = Roof or Wall heat transfer coefficient $W/m^2 \circ C$ (T19) $A_R =$ Roof or Wall area m^2 $(T_i - T_o) =$ Outdoor, indoor Temperature $^{\circ}C$

3. HEAT LOSS –FLOORS a– FLOOR AREA

$$\boldsymbol{Q}_{t/F} = \mathbf{U} \mathbf{A}_{\mathrm{F}} (\mathbf{T}_{\mathrm{i}} - \mathbf{10})$$



3. HEAT LOSS –FLOORS b- FLOOR EDGES

$$Q_{t/F} = 0.8 P (T_i - 10)$$



4. Heat Transmission Partition

$$Q_{t/P} = U A_P (T_i - T_o - 9)$$



5- Infiltration

- 5. INFLITRATION
- i- Depending on windows or doors area:



ii- Depending on the crack length L_C

Depends on figure 6, for single hung window or door, crack length can be calculated as follows:

 $L_{C}=2.(H+W)$

While for double hung window or door

LC=2.(H+W) +H

LC=2.(H+W)+H

I	$OA = No L_c$	7		
		Volume flow rate/ m		T(24)
		Number of window	-	
		and doors		
		Outdoor air	Lit/s	



Figure 6 single and double hung windows

6- Ventilation:

i- Outdoor air ventilation depending on the number of people:

V	=	No	R_P			
				Volume flow rate/ person	Lit/s per Person	T(25)
				Number of People	-	
				Outdoor air	Lit/s	

ii- Outdoor air ventilation depending on the floor area



A- Outdoor Air Sensible heat OASH

Q_s	=	1.2	VOA	$(T_i - T_o)$			
					Outdoor, indoor	°C	
					Ventilation rate	Lit/s	
					Factor		
					Outdoor Air Sensible heat	W	

B- Outdoor Air Latent Heat OALH

Q_l	=	3000	VOA	$(g_i - g_o)$		
					Moisture content	kgw/kga
			-		Ventilation rate	Lit/s
					Factor	
	-				Outdoor Air Sensible heat	W

C- Outdoor air Total Heat OATH

Q_T	=	1.2	VOA	$(h_i - h_o)$		
					enthalpy	Kj/kg
					Ventilation rate	Lit/s
					Factor	
					Outdoor Air Sensible heat	W

6- TOTAL HEATING LOAD

$$\sum Q_g + Q_d + Q_{wall} + Q_{Floor} + Q_{Roof} + Q_{Ventilation}$$

Example 3.

A single-family detached house shown in Fig. 1a is located in Iraq-Baghdad. The Wall is built from of 13 mm cement plaster, 20 cm common brick and 10 mm gypsum plaster. While the **Partition** is built from **10 cm common brick** and 10 mm gypsum plaster on both sides. The Roof is built from outside to inside from 10 mm cement tail, 130 mm sand, 10 mm Expanded polyurethane, Asphalt shingles, 150 mm concrete and 20 mm gypsum. The floor consist from outer to inner from carp, cement tile of 25 mm thick., heavy concert of 15 cm thick. Ceiling height is 3 m Fenestration. Clear single glass, 3 mm thick. Assume closed, medium-color well fitted, aluminum frame. *Doors* made of wood of 25 mm thickness. *Occupancy*. Four persons, based on two for the master bedroom and one for each additional bedroom. Assign to the living room. Llights. Assume 480 W for the kitchen, and 480 W for living room, assign 50% to bed room 1, 25% for bedrooms 2 and 3. Appliances : there is one TV, PC laptop, laser printer, and Coffee brewer in living room, The construction of the house is considered medium. Find the sensible, latent, and total Heating load; size the heating unit; and compute the air quantity for each room.



Msc. Zahraa F. Hussain



Area of Building

Room	Net area of outer Walls (m²)					Windows					Roof (m ²)	Perimeter	Partition
nanc	W	E	N S W E N S Door										
Bed R1	17.4	-	-	-	3.6	-	-	-	2.1	50.75	50.75	2(7+7.25)=28.5	18.9
Living room	12.9	-	20.55		3.6	-	-	-	4.2	45.38	45.34	27.5	-
Bed R2	-	10.8	-	8.55	-	2.7	-	2.7	2.1	16.88	16.88	16.5	11.4
Bed R3	-	10.8		-		2.7			2.1	16.88	16.88	16.5	11.4 11.25



Msc. Zahraa F. Hussain

The floor consist from outer to inner from carp, cement tile of 25 mm thick., heavy concert of 15 cm thick

L	K	Р	R	Mass
mm	W/mK	kg/m ³	$m^2 K/W$	kg/m ²
150	1.731	2243	0.088	341.60
	0.000		0.121	0.00
25			0.71	
10	0.27	1921	0.037	23
	L mm 150 25 10	L K mm W/mK 150 1.731 0.000 25 10 0.27	$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$

Carpet

 $R_{\text{Carprt}} = 0.71 \ m^2 K/W$

Concrete Tile

 $x = 250 \ mm$

 $k_{\text{tile.}} = 0.1$

$$R_{\text{tile.}} = \frac{x}{k} = \frac{0.025}{0.27} = 0.1 \ m^2 K/W$$

high density concrete

x = 150 mm

 $R_{\rm Conc} = 0.088 \qquad m^2 K/W$

Inside resistance

 $R_i = 0.121 \ \frac{m^2 K}{W}$

Overall heat transfer coefficient and weight of exposed roof

$$R_e = R_i + R_{carpt} + R_{tile} + R_{conc}$$

 $R_e = 0.121 + 0.71 + 0.1 + 0.088 = 1.019$

$$U_{floor} = \frac{1}{1.019} = 0.98 W/m^2 K$$

Outer wall	Partition	Roof	Window	Door	Floor
U	U	U	U	U	U
W/m².K	W/m².K	W/m².K	W/m².K	W/m².K	W/m².K
1.916	2.45	1.457	6.42	3.92	0.98

Heating Load Building: Home Room name: Bed Room 1Indoor Design condition 23°C& RH 50 %Outdoor Design condition 1.5 °C& RH 84%

	Heat Loss												
Eq	Q		U		Α		ΔT						
1	Q/ Glass	=	6.42	×	3.6	×	21.5	=	496.908 W				
2	Q/ Door	=		×		×		=	0				
3	Q/Wall	=	1.916	×	17.4	×	21.5	=	716.776 W				
4	Q/Roof	=	1.457	×	50.75	×	21.5	=	1589.77 W				
5	Q/Partitions	=	2.45	×	21.75	×	12.5	=	666.1W				

	Floor											
	Q		U		Α		ΔT					
6	Q/Floor edges	Η	0.8	×	28.5	×	13	Π	296.4 W			
7	Q/Floor base area	Η	0.98	×	50.75	×	21.5	Ξ	1069.3 W			

Ventilation and infiltration

	Lc	=	Nos.	X	fac		(L +	H)	+	Η		
	Lc		1		2		0.6	1		0		3.2
	ΙΟΑ	Η	3.2	×	0.3				Η		0.96	
	V	Ш	2	x	2.5			1	=		5	
	VOA	=	Lit/s	+				Lit/s	=		5.96	
			F		VOA			ΔT				
7	OASH	II	1.21	×	5.96		×	21.5	=		155.049	W
			F		VOA	L		Δω				
8	OALH	=	3000	×	5.96		×	0.00506	=		90.4728	W
	OATH	=		+			=		=		245.522	W
10	Total Load	=							=		5081	W